



# Descriptive Report and Test Results

**MASTER CONTRACT: 222826**

**REPORT: xxxxxxxx**

**PROJECT: xxxxxxxx**

**Edition 1:** Date; Project xxxxxxxx – Atlanta  
Issued by Tim Gentry

Contents:

## **PRODUCTS**

CLASS 3402 03 – LUMINAIRES – LED – For Wet Locations

CLASS 3402 83 – LUMINAIRES – LED – For Wet Locations – Certified to US Standards

Cat. No. ATBX Series – Wet Location, Arm Mounted LED Luminaire rated 120 to 277V ac, 50/60 Hz, Max. 55W. Provided with one LED Array, aka COB. Suitable for use in a maximum 40° C ambient. May be provided with Photocontrol Receptacle, or 7 Pin dimming capable Photocontrol Receptacle (P7 Option). May be provided with Surge Protectors and optional dimming devices Luminaire may be provided with various Type optic lenses. May be provided with optional house-side shield (HS) or visual comfort shield (VR) or light trespass shield (LTS).

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 250.0-08 – Luminaires

UL 1598, 3<sup>rd</sup> Ed. – Luminaires

CSA C22.2 No. 250.13-17 – Light Emitting Diode (LED) Equipment for Lighting Applications

UL 8750, 2<sup>nd</sup> Ed. – Light Emitting Diode (LED) Equipment for use in Lighting Products

This report shall not be reproduced, except in full, without the approval of CSA Group.

6215 Shiloh Crossing, Building 100, Suite A, Alpharetta, GA, U.S.A 30005  
Telephone: 678.992.0134 1.800.463.6727 Fax: 770.500.3948 www.csagroup.org